

MARCH 6, 2007 RE-ISSUED JULY 20, 2010

BIO-MICROBICS, INC.  
ALLISON BLODIG  
8450 COLE PKWY.  
SHAWNEE KS 66227

**Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER \***  
Manufacturer: BIO-MICROBICS, INC.  
Product Name: SANITEE  
Model Number(s): SNT 416, SNT 418  
[4 IN. DIA., FLOW RANGE UP TO 1000 GPD AND 2000 GPD, RESPECTIVELY;  
**SCREENS PARTICLES UP TO 1/16 IN. AND 1/8 IN., RESPECTIVELY]**  
Product File No: 20070074

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of MARCH 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- A means of venting the gases formed inside of the tank in which this product is installed shall be provided in accordance with s. Comm 84.25 (5), of the Wisconsin Administrative Code.
- This product must be installed in accordance with the manufacturer's installation instructions and with the bottom of the product above the scum level in the tank.

This approval supersedes the approval issued on MARCH 9/2005/MARCH 2, 2007 under product file number 20050019/20070074. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050019/20070074.

**\* TO ASSIST USERS IN ON-LINE SEARCHES FOR COMMERCE PLUMBING PRODUCT APPROVALS AND TO BETTER DESCRIBE THIS PART/DEVICE, AS OF THE DATE OF THIS COMMUNICATION, THIS PRODUCT TYPE DESCRIPTION HAS BEEN CHANGED FROM SEWAGE TREATMENT APPARATUS (STA) TO SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER (STAF); SEE ALSO [http://commerce.wi.gov/php/sb-ppalopp/prodcode\\_alpha\\_list.php](http://commerce.wi.gov/php/sb-ppalopp/prodcode_alpha_list.php).**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Products Review  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@WI.GOV\